

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

The City of Haltom City has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During June 1, 2015 – September 30, 2015 we did not monitor or test for Lead & Copper and therefore cannot be sure of the quality of your drinking water during that time.

The table below lists the contaminants we did not properly test for during the last year, how often we are supposed to sample for Lead & Copper, how many samples we are supposed to take, how many samples, we took, when samples should have been taken, and the date on which the follow-up samples will be taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples will be taken
Lead & Copper tap water sampling	30 samples every three years	0	June 1, 2015 – September 30, 2015	June 1, 2016 – September 30, 2016

What is being done?

We are working to correct the problem. For more information, please contact [David Cummings](#) at (817) 834-9036 or at the [Haltom City Public Works Service Center](#), 4200 Hollis Street, Haltom City 76111.

Presently, the City only has one employee responsible for Lead & Copper tap water sampling. Starting with the samples required this summer and then moving forward, the City will require at least two employees to share in the responsibility to have the Lead & Copper tap water sampling completed every three years.

This notice is being sent to you by [the City of Haltom City](#). Public Water System Number: 2200014.